



NOTES:

1. METER MUST BE INSTALLED HORIZONTALLY.
2. PLUMBER IS RESPONSIBLE FOR SUPPLYING STRAIGHT METER SPUDS SPACED TO ACCEPT THE APPROPRIATE SIZE METER.
3. IF A COMMERCIALLY MANUFACTURED METER YOKE IS USED IT CAN BE VERTICAL SETTER OR HORIZONTAL SETTER HOWEVER THE METER MUST BE INSTALLED HORIZONTALLY.
4. METER YOKE OR SPUDS TO BE PROVIDED WITH VALVES ON BOTH SIDES OF THE METER.
5. METER YOKE TO BE PROVIDED WITH SADDLE NUTS TO FACILITATE INSTALLATION OF THE METER.
6. IF A COMMERCIAL METER YOKE IS USED IT SHOULD BE COPPER HORN AS MANUFACTURED BY THE FORD METER BOX COMPANY OR BASEMENT SETTING METER YOKE AS MANUFACTURED BY THE MUELLER COMPANY OF DECATUR ILLINOIS.

REVISED 10-08-03 CADD DRAWING BY GTS CONSULTANTS, INC.

DATE: JAN. 1991

DRAWN: G.G.&J.T.R.

SCALE: NONE

LAKWOOD TOWNSHIP
MUNICIPAL UTILITIES AUTHORITY

INSIDE RESIDENTIAL
METER INSTALLATION