



NOTES:

1. INTERIOR SURFACES TO BE COATED WITH TWO COATS, 18 MIL TOTAL, COAL TAR EPOXY MEETING SPECIFICATION C-200(A) OR SSPC-PAINT 16 IF RECEIVING DIRECT DISCHARGE FROM PUMP STATION OR DIFFERENCE IN INVERT ELEVATIONS EXCEEDS 12".
2. RISER, CONES AND SLABS SHALL BE CONSTRUCTED IN ACCORDANCE WITH A.S.T.M. C-478.
3. NON PENETRATING LIFTING HOLES SHALL BE PROVIDED IN ALL UNITS.
4. ABSORPTION NOT TO EXCEED 8% IN ACCORDANCE WITH A.S.T.M. C-76.
5. ALL JOINTS TO BE CONSTRUCTED IN ACCORDANCE WITH A.S.T.M. C-361.
6. NO PRE-CAST BENCHES OR CHANNELS

REVISED 06-14-07	ADDED NOTE No. 6
REVISED 10-08-03	CADD DRAWING BY GTS CONSULTANTS, INC.
DATE: JAN. 1991	LAKWOOD TOWNSHIP MUNICIPAL UTILITIES AUTHORITY
DRAWN: G.G.&J.T.R.	
SCALE: NONE	

CONE TOP MANHOLE

19