



FIRE HYDRANT NOTES:

1. FIRE HYDRANT SHALL BE MUELLER MODE A-423 SUPER CENTURION 200 OR EQUAL.
2. CONTRACTOR SHALL TAKE CARE THAT THE DRAIN RING SHALL NOT BE OBSTRUCTED.
3. TO MAINTAIN 5 FEET OF COVER HYDRANT BURY LENGTH SHALL BE A MINIMUM OF 5 FEET 6 INCHES.
4. HYDRANTS LOCATED AT A DISTANCE GREATER THAN 30 FEET FROM THE WATER MAIN MUST HAVE SHUT-OFF VALVE AT THE WATER MAIN AND WITHIN 8 FEET OF THE HYDRANT.
5. ANY PIPE JOINTS BETWEEN THE SHUT-OFF VALVE AND THE FIRE HYDRANT MUST BE RESTRAINED. THE TYPE OF RESTRAINT MUST BE SPECIFIED ON THE PLANS.

REVISED 10-08-03 CADD DRAWING BY GTS CONSULTANTS, INC.

DATE: JAN. 1991

DRAWN: G.C.&J.T.R.

SCALE: NONE

LAKWOOD TOWNSHIP  
MUNICIPAL UTILITIES AUTHORITY FIRE HYDRANT DETAIL 2