



**NOTES:**

1. LADDERS SHALL BE INSTALLED ON ALL MANHOLES WHERE THE DISTANCE FROM THE INVERT TO THE RIM EXCEEDS 15 FEET.
2. LADDER SHALL BE FIBERGLASS.
3. CLIPS, ANGLES, BOLTS, WASHERS AND ALL OTHER HARDWARE SHALL BE 304 STAINLESS STEEL.
4. ALL MANHOLES EXCEEDING 25 FEET FROM INVERT TO RIM SHALL HAVE AT LEAST ONE INTERMEDIATE PLATFORM.

REVISED 10-08-03		CADD DRAWING BY GTS CONSULTANTS, INC.	
DATE: JAN. 1991	LAKESWOOD TOWNSHIP MUNICIPAL UTILITIES AUTHORITY		FIBERGLASS MANHOLE LADDER DETAIL
DRAWN: G.G.&J.T.R.			
SCALE: NONE			23