



NOTES:

1. BENCH TO HAVE 2.0% SLOPE (TYP.) WITH NON SKID SURFACE.
2. ALL CONNECTIONS TO BE MADE WITH CONICAL TYPE FLEXIBLE SEAL SUCH AS KOR-N-SEAL OR EQUAL.
3. ALL CHANNELS MUST BE HALF PIPE OR EPOXY COATED.
4. THE MANHOLE MUST MEET ALL REQUIREMENTS FOR MANHOLE CONSTRUCTION SHOWN ON THE OTHER DETAILS OF THE AUTHORITY INCLUDING BUT NOT LIMITED TO THE REQUIREMENT FOR 12" OF CRUSHED STONE TO BE PLACED UNDER THE NEW MANHOLE.

REVISED 12-13-02 CADD DRAWING BY GTS CONSULTANTS, INC.

DATE: JAN. 1991
 DRAWN: G.G.&J.T.R.
 SCALE: NONE

LAKWOOD TOWNSHIP
 MUNICIPAL UTILITIES AUTHORITY

MANHOLE INSTALLED ON
 EXISTING SEWER