



NOTES:

1. INTERIOR SURFACES TO BE COATED WITH TWO COATS, 18 MIL TOTAL, COAL TAR EPOXY MEETING SPECIFICATION C-200(A) OR SSPC-PAINT 16 IF RECEIVING DIRECT DISCHARGE FROM PUMP STATION OR DIFFERENCE IN INVERT ELEVATIONS EXCEEDS 12".
2. RISERS SHALL BE CONSTRUCTED IN ACCORDANCE WITH A.S.T.M. C-478.
3. NON PENETRATING LIFTING HOLES SHALL BE PROVIDED IN ALL UNITS.
4. ABSORPTION NOT TO EXCEED 8% IN ACCORDANCE WITH A.S.T.M. C-76.
5. ALL JOINTS TO BE CONSTRUCTED IN ACCORDANCE WITH A.S.T.M. C-361.
6. NO PRE-CAST BENCHES OR CHANNELS
7. FRAME AND COVER TO BE CAMPBELL FOUNDRY MODEL No. 4456 OR EQUAL WITH "FLOW-SEAL" FEATURE AND MUST HAVE "L.T.M.U.A." AND YEAR CAST INTO COVER IN 2 INCH LETTERS. IF MANHOLE IS NOT OWNED BY THE AUTHORITY, REPLACE "L.T.M.U.A." LETTERING WITH "SANITARY SEWER."
8. MUST BE USED AT DEPTHS OF 6.5' AND SHALLOWER AS MEASURED FROM RIM TO INVERT.

DATE: JULY, 2011
 DRAWN: SGM OF GTS
 SCALE: NONE

**LAKEWOOD TOWNSHIP
 MUNICIPAL UTILITIES AUTHORITY**

SHALLOW MANHOLE

38