



\*\* BALL VALVES AND COMPRESSION FITTINGS MAY BE ACCEPTED  
 ++ 1 1/2" & 2" LINES REQUIRE DOUBLE STRAP TAPPING SADDLE FOR ALL SIZE LINES  
 SADDLES REQUIRED ON ALL TAPS FOR LINES LESS THEN 8" IN DIAMETER

LINE DIA.	MUELLER		McDONALD	
	CURB BOX	LID	CURB BOX	LID
1"	H-10314 W/ ROD	89982	5601	5601L
1-1/2"	H-10314 W/ ROD	89982	5601	5603L
2"	H-10310 W/ ROD	89981	5603	5601L

1. CURB BOX SHALL NOT BE LOCATED IN THE SIDEWALK, ROADWAY OR CURB.
2. CURB BOX SHALL BE LOCATED BEHIND THE SIDEWALK FOR INTEGRAL CURB AND SIDEWALK.
3. IN GENERAL, THE CURB BOX SHOULD BE LOCATED BETWEEN THE CURB AND SIDEWALK.
4. DESIGNER MUST RESEARCH ANY PROPOSED WIDENING OF EXISTING ROADWAYS AND LOCATE BOXES TO COMPLY WITH NOTES 1, 2 AND 3.
5. FOR PUBLIC RIGHTS-OF-WAY, THE AUTHORITY'S RESPONSIBILITY FOR MAINTENANCE SHALL BE LIMITED TO THE WATER MAIN, CORPORATION STOP, SERVICE LINE TO AND INCLUDING THE CURB STOP. THE MAINTENANCE OF THE CONNECTION OF THE SERVICE FROM THE CURB STOP TO THE BUILDING SHALL BE THE RESPONSIBILITY OF THE PROPERTY OWNER. FOR PRIVATE ROADWAYS, MAINTENANCE OF THE SERVICE LINE FROM ITS CONNECTION TO THE CORPORATION IS THE RESPONSIBILITY OF THE PROPERTY OWNER.
6. THE CONTRACTOR IS RESPONSIBLE FOR ALL PERMITS AND NOTIFICATION OF ALL APPROPRIATE AGENCIES.
7. THE CONTRACTOR IS RESPONSIBLE FOR NOTIFYING THE AUTHORITY AND THE TOWNSHIP PLUMBING DEPARTMENT FOR INSPECTION AT LEAST 48 HOURS IN ADVANCE OF THE WORK BEING PERFORMED.
8. SERVICE CONNECTION LARGER THAN 2 INCHES SHALL BE DUCTILE IRON PIPE WITH STANDARD GATE VALVE AND BOX.
9. SERVICE LINE SHALL BE A MINIMUM OF 1 INCH TYPE "K" COPPER FROM THE WATER MAIN TO THE OUTLET SIDE OF THE CURB STOP. FOR OUTSIDE METER PITS, SEE DETAIL.

REVISED 07-05-05	REVISED CURB BOX, CORP STOP & CURB STOP
REVISED 10-08-03	CADD DRAWING BY GTS CONSULTANTS, INC.