

**Addendum No. 27 Summary**  
**May 1, 2018**  
**REVISIONS TO THE LTMUA RULES & REGULATIONS**

The following sections are to be created/revised as follows:

**5.20 METER PITS AND METER VAULTS**

For all meters up to 1" in size the meter pit shall be the Ford Meter Box Company Coil Pit Setter with H-20 Rated Composite Flat Lid with Plastic ERT Bracket #PPSC-18-L-P-BR or Approved Equal. Meter pit depth must be a minimum of 60" regardless of actual water service line depth. Please refer to the Authority Approved "5/8" or 1" Meter Pit Detail."

For all meters 1 ½" and 2" in size the meter pit shall be the Ford Meter Box Company Plastic Pit Setters for 1 ½" and 2" Meters with Monitoring Cover with Electronic Meter Reading Lid with Plastic Inner Lid #MC-36-P-BR or Approved Equal. The heavier lid for driveway traffic and the Ford Insulating Disc are required. Meter pit depth must be a minimum of 60" regardless of actual water service line depth. Please refer to the Authority Approved "1 ½" or 2" Meter Pit Detail."

For all meters and fire lines larger than 2" in size the meter and/or fire line with detector check must be installed in a prefabricated concrete vault by Fab-Crete as indicated on the Authority construction details for meter vaults or Approved Equal.