

Addendum No. 34 Summary
October 8, 2019
REVISIONS TO THE LTMUA RULES & REGULATIONS

The following sections are to be revised as follows:

3.04 GENERAL REQUIREMENTS FOR WATER LATERAL & WATER MAINS

- (4) A minimum of 5' separation must be provided between all water mains and laterals that are owned, operated and/or maintained by the Authority from other utilities including but not limited to natural gas, electric, cable, fiber optic, storm water, etc.

3.05 GENERAL REQUIREMENTS FOR SEWER LATERAL & SEWER MAINS

- (4) A minimum of 5' separation must be provided between all sanitary sewer mains and laterals that are owned, operated and/or maintained by the Authority from other utilities including but not limited to natural gas, electric, cable, fiber optic, storm water, etc.