



NOTES:

1. FILL VOID WITH WEST SYSTEM'S G/FLEX 655 EPOXY ADHESIVE UP TO THE SPRING LINE OF THE PIPE.
2. PORTLAND CEMENT MAY BE ADDED TO THE EPOXY ADHESIVE IN ACCORDANCE WITH THE MANUFACTURER'S SPECIFICATIONS.
3. BENCH TO HAVE 2.0% SLOPE TOWARD CHANNEL(S) (TYP.) WITH NON SKID SURFACE.
4. ALL SLEEVE CONNECTIONS TO BE MADE WITH CONICAL TYPE FLEXIBLE SEAL SUCH AS KOR-N-SEAL OR EQUAL.
5. ALL CHANNELS MUST BE HALF PIPE OR EPOXY COATED.
6. THE MANHOLE MUST MEET ALL REQUIREMENTS FOR MANHOLE CONSTRUCTION SHOWN ON THE OTHER DETAILS OF THE AUTHORITY INCLUDING BUT NOT LIMITED TO THE REQUIREMENT FOR 12" OF CRUSHED STONE TO BE PLACED UNDER THE MANHOLE AND TO EPOXY-COAT THE BENCH & CHANNEL.