



JCM 210 OR 212  
DUCTILE IRON COUPLING  
OR APPROVED EQUAL

## DUCTILE IRON TRANSITION COUPLINGS

**NOTES:**

1. SLEEVE AND FLANGES MUST BE DUCTILE IRON MEETING SPECIFICATION A.S.T.M. A-536.
2. NUTS AND BOLTS MUST BE STAINLESS STEEL 18-8, TYPE 304 OR 316, OR APPROVED EQUAL.
3. CONTRACTOR IS RESPONSIBLE TO VERIFY THE DIAMETERS OF THE PIPES TO BE CONNECTED AND ORDER THE APPROPRIATE COUPLING.
4. STAINLESS STEEL TRANSITION COUPLING ARE ACCEPTABLE. ALL STAINLESS STEEL TRANSITION COUPLINGS MUST BE 304 STAINLESS WITH STAINLESS STEEL NUTS, BOLTS AND WASHERS.
5. IN AREAS WHERE THE PIPE MATERIALS ALLOW THEIR USE, THE PIPES MUST BE CONNECTED USING A MECHANICAL JOINT SOLID SLEEVE AND BE RESTRAINED IN A MANNER FOUND ACCEPTABLE TO THE ENGINEER.

REVISED 7-14-11	REVISED NOTES 2 AND 5
REVISED 10-08-03	CADD DRAWING BY GTS CONSULTANTS, INC.
DATE: JAN. 1991	<b>LAKWOOD TOWNSHIP MUNICIPAL UTILITIES AUTHORITY</b>
DRAWN: G.G.&J.T.R.	
SCALE: NONE	